

**FIRE PREVENTION WING - FIRE NO OBJECTION CERTIFICATE**File. No: **2021-TRF-115556**

Name and Address of the Premises:	N.S.M. Public School, Patamata, Vijayawada.
Name of the Owner / Occupier:	Bro.Lawrence D' Souza

**Details of Building:**

Plot Area (in Sq. Meters)	6.8 acres
No. of Blocks	ONE
Height of the Building from abutting road level to terrace (in meters)	11.34 Meters

**Floor Wise Occupancy details**

S.No.	Floor	Built up area (in Sq. Meters)	Type of Occupancy
1.	Ground Floor	3890.66	Educational
2.	First Floor	3890.66	Educational
3.	Second Floor	3890.66	Educational

**Open spaces in Meters**

Front	02.00	Back	00.00	Side - 1	151.86	Side - 2	03.00
-------	-------	------	-------	----------	--------	----------	-------

**Means of Escape (Staircase)**

S No.	Details of Staircases	Provided	
		Number	Width in meters
1.	No of Staircases	11	17.10

**Fire Fighting Equipment as show in the Annexure**

Renewal of No Objection Certificate is hereby Issued along with Annexure Under Section 13 of Andhra Pradesh Fire Service Act, 1999 and under Rule 15 of Andhra Pradesh Fire and Emergency Operations and Levy of Fee Rules 2006 to the above Premises within the Jurisdictions of Vijayawada Municipal Corporation subject to the Maintenance of Fire Fighting Equipment in Good Working and other conditions and details Mentioned in the Annexure.

No Objection Certificate is valid up to **02/10/2024** or till it has been duly cancelled (Whichever is earlier)

PRINCIPAL

N.St.Mathew's Public School  
VIJAYAWADA-520010

Commissioner,  
Vijayawada Municipal Corporation.

**VIJAYAWADA MUNICIPAL CORPORATION**  
**FIRE PREVENTION WING**  
**ANNEXURE TO FIRE NO OBJECTION CERTIFICATE(RENEWAL)**  
**Rc.No.2021-TRF-115556 Dated:25-10-2021.**

**Sub:** Vijayawada Municipal Corporation – Fire Prevention Wing - Issuance of Annexure to **Renewal** of No Objection Certificate for Occupancy to the Existing Educational Building of N.S.M. Public School, Patamata, Vijayawada, Krishna District - Regarding.

- Ref:** 1. N.O.C.for Occupancy Rc.No.52/FPW/VMC/2012 Dt: 03-10-2012 of the Commissioner, Vijayawada Municipal Corporation.  
2. Revised NOC for Occupancy Rc.No.37903048032, Dt:29-05-2018 of the Commissioner, Vijayawada Municipal Corporation.  
3. Ack.No.2021-TRF-115556 Dt: 15-09-2021 of the Bro.Lawrence D'Souza, Principal N.S.M.Public School, Patamata, Vijayawada, Krishna District.  
4. Inspection Report Rc.No.2021-TRF-115556, Dt: 21-10-2021 of the Officials of Fire Prevention Wing, Vijayawada Municipal Corporation.  
5. G.O.Ms.No.154, M.A & U.D Dept. Dt.13-03-2007.  
6. G.O.Ms.No.174, M.A & U.D Dept. Dt. 24-02-2009.  
7. G.O.M.s.No.169,HOME(PRISONS&FIRE)Dept,Dt:19-12-2019.  
8. G.O.M.s.No.90,HOME(PRISONS&FIRE)Dept,Dt:13-08-2021.

\*\*\*\*\*

Vide reference 1<sup>st</sup> and 2<sup>nd</sup> cited NOC for Occupancy and revised NOC for Occupancy respectively has given to Existing Education Building N.S.M. Public School, Patamata, Vijayawada, Krishna District.

Vide reference 3<sup>rd</sup> cited, Bro.Lawrence D'Souza, Principal N.S.M. Public School of Education has requested for issue of Renewal No Objection Certificate for Occupancy to the Existing Education Building N.S.M. Public School, Patamata, Vijayawada, Krishna District.

Vide reference 4<sup>th</sup> cited the Officials of Fire Prevention Wing have reported that they have inspected the building on 21-10-2021 and recommended for the issuance of Renewal of No Objection Certificate for Occupancy for the above Educational Building.

**PART – A: GENERAL INFORMATION**

1.	Name and Address of the Building with Land Marks	N.S.M. Public School, Patamata, Vijayawada, Krishna District.			
2.	Name and Address of Builder/ a)Developer/Owner  b)Occupier/Tenant and Telephone No.s	Bro.Lawrence D'Souza, Principal N.S.M. Public School, Patamata, Vijayawada, Krishna District. Cell No. 9440287708			
3.	Details of the Management/ Representative present at the time of Inspection	Sl. No.	Name	Designation/ Working as	Contact No.
		1.	Bro.Lawrence D'Souza	Principal	9440287708
4.	Plot Area(in Sq. Meters)	6.8 acres			
5.	No. of Blocks	ONE			
6.	Height of the Building from abutting road level to terrace(in meters)	11.34 Meters			

(Contd..P2)

**PART – B: BUILDING INFORMATION****1.a). Floor Wise Occupancy details: ( Educational Building)**

Sl. No.	Floor	Built up area (in Sq.Meters)	Type of Occupancy	Occupant Load
1.	Ground Floor	3890.66	Educational	973
2.	First Floor	3890.66	Educational	973
3.	Second Floor	3890.66	Educational	973

**b). Open spaces:**

Side	Open Space Required as per G.O.168	Open space available	Deficit
East (Front)	06.00 Meters	02.00 Meters	Additional Fire Safety Measures Provided for deficient open spaces as per G.O.MS.NO.154,MA & UD Dt:13-03-2007
West	06.00 Meters	NIL	
North	06.00 Meters	151.86 Meters	
South	06.00 Meters	03.00 Meters	

**2. Means of Escape (Staircase):**

Sl. No.	Details of Staircases	Provided	
		No.s	Width in meters
1.	No of Staircases	11 No.s	17.10 Meters

**Details of Fire Precautionary Fees remitted:**

Sl.No.	DD. No.	Date	Amount	Place
1.	205172	22-10-2021	1,75,500/-	Federal Bank, VIJ

**PART – C: FIRE PROTECTION AND FIRE PRECAUTIONARY MEASURES:**

Minimum Fire Fighting Installations required as per Table-23, Part-IV of NBC-2005.

	Sl No	Fire Fighting Installations	Required	Provided	Deficit
Part A	i	Fire Extinguishers	117 No.s	117 No.s	NIL
	ii	Hose Reel	24 No.s	24 No.s	NIL
	iii	Terrace Tank	25,000 Ltrs	25,000 Ltrs	NIL
	iv	Electrical Pump of 900LPM	03 No.s	03 No.s	NIL
Part B (Additional Fire Safety)	v	Manually operated electric Fire Alarm System	24 No.s	24 No.s	NIL
	vi	Yard Hydrant	08 No.s	08 No.s	NIL

(Contd..P3)

The Existing Education Building N.S.M. Public School, Patamata, Vijayawada, Krishna District is provided with required fire safety measures.


The Fire Safety systems were tested by the committee members during the inspection and Performance found satisfactory. Therefore, this Office has issued Annexure to Renewal of No Objection for Occupancy to N.S.M. Public School, Patamata, Vijayawada, Krishna District. Subject to the following conditions.


i	All the Fire protection arrangements shall be maintained in good working condition as seen during inspection.
ii	The escape/ exit routes shall not be kept locked/ blocked or encroached.
iii	All the occupants must know the correct method of operation of the fire fighting system.
iv	Any loss of life or property due to non-functioning of fire safety measures and other installations shall be the responsibility of the management.
v	All Staff members of the institution shall be trained to operate the fire safety equipments during emergency.
vi	Addition/ alteration if any in the building shall be carried only with the prior permission from this Department.
vii	Mock drills should be conducted once in for every 3 months.
viii	The management has to submit annual fire audit report by checking all fire systems satisfactory working condition in premises.
ix	Fire extinguishers to be certified every year from licensed authority.
x	Emergency Contact Number of Nearest Fire Station to be displayed.


This Renewal of No Objection Certificate for Occupancy is valid up to 02-10-2024 (For a period of three years only) as per G.O.M.s.No.169,HOME(PRISONS&FIRE) Dept, Dt:19-12-2019. The Owner / Occupant shall submit application for its renewal duly remitting the prescribed fees, as per G.O.Ms.No. 71, Home (Prisons – A) Dept. Dt. 01-04-2010, two months before the date of renewal.

The Annexure to No Objection Certificate Renewal of is with regard to fire safety only and this is not valid for other claims.

  
 PRINCIPAL  
 N.St.Mathew's Public School  
 VIJAYAWADA-520010

  
 Regional Fire Officer, 26/10/2024  
 Fire Prevention Wing,  
 Vijayawada Municipal Corporation.

  
 25/10/2024  
 DPO

  
 25/10/24