

Sub:- Vijayawada Municipal Corporation - Fire Prevention Wing - Issuance of Periodical Occupancy Renewal Certificate to the Existing Non Multi Storied Educational building of N.St. Mathew's Public School located at D.No. 69-1-5A,Patamata,Vijayawada (City) - NTR District - Reg.

- Ref:-**
- (1) A.P. Fire Services Act,1999.
 - (2) A.P. Fire and Emergency Operations and Levy of Fee Rules,2006.
 - (3) Proceedings Rc.No.5041/B2/97,dated:12-03-2010 of the Director General of State Disaster Response and Fire Services, A.P., Hyderabad.
 - (4) Circular Memo Rc.No.3350/Audit/NOC/2012,dated:02-05-2023 of the Director General of State Disaster Response and Fire Services, A.P., Vijayawada.
 - (5) GO. Ms.No.218,Dt: 22-12-2023 of Home(Prisons & Fire)Department.
 - (6) No Objection Certificate for Occupancy issued vide this Office Rc No. 52/FPW/VMC/2012, dated:03-10-2012.
 - (7) Last Renewal of No Objection Certificate for Occupancy issued vide this Office Rc No. 2021-TRF- 115556, dated:27-10-2021.
 - (8) Change of Name from N.S.M. Public school to N.St. Mathew's Public School issued Vide this Office Rc. No.2023-TRF-116389,dated: 28-12-2023.
 - (9) Application received from the Bro. Rayapureddy Singareddy, Principal, N.St. Mathew's Public School,D.No.69-1-5A, Patamata, Vijayawada (City), NTR District, dated:17-09-2024.
 - (10) Inspection Committee Report of Fire Prevention Wing vide Rc No. 62/FPW/ICR/2024, dated:29-10-2024.

-x x x-

It is to inform that, in the reference 9th cited, the Management has requested to issue Periodical Renewal Certificate to the Existing Non-Multi Storied Educational building of N.St. Mathew's Public School located at D.No.69-1-5A,Patamata,Vijayawada (City), NTR District.

- (2) Vide reference 10th cited, the Inspection Committee of Fire Prevention Wing has inspected the Existing Non Multi Storied Educational building of N.St. Mathew's Public School located at D.No.69-1-5A,Patamata,Vijayawada (City), NTR District on dt:23-09-2024 and submitted the following report.

- (i) Vide References 6th,7th and 8th cited, the Management has obtained No Objection Certificate for Occupancy and Last Renewal of No Objection Certificates for Occupancy and Change of Name from N.S.M. Public school to N.St. Mathew's Public School from this Office from to the above said Educational building.
- (ii) The above said Existing Non Multi Storied Educational building was constructed with RCC Roof with a height of 11.34 Mtrs with Ground + 02 Upper floors and the total built up area is 11,671.98 Sq Mtrs for Educational Occupancy.
- (iii) As per references 6th,7th cited, the Management has provided Fire safety and Properly maintained Floor wise Occupancy and Means of Escape for the above said Educational building.
- (iv) **The Management has provided the following Fire Fighting Systems as per NBC:**

SI No	Fire Fighting Installations	Required	Provided	Defic-it
(1)	(2)	(3)	(4)	(5)
(i)	Fire Extinguishers	59 No's	59 No's	Nil
(ii)	Down Comer	06 No's	06 No's	Nil
(iii)	First Aid Hose Reels	18 No's	18 No's	Nil
(iv)	Manual Operated Electrical Fire Alarm Systems	18 No's	18 No's	Nil
(v)	Terrace Tank of Water Capacity (in Ltrs)	25,000 x 2 No's	25,000 x 2No's	Nil
(vi)	Terrace pump of Capacity	900 LPM x2No's	900 LPMx2 No's	Nil
(vii)	Two Way Fire Brigade inlet Valve	Required	Provided	Nil
(viii)	Yard Hydrants	Required	Provided	Nil

- (3) The Management has provided Fire Safety Measures as per Part-IV of NBC of India, G.O Ms No.119, MA & UD Department,dated:28-03-2017 and Government Memo No.4011,MA & UD Department,dated:19-05-2008 and the Inspection Committee has tested the Fire Safety Measures and found in working condition and recommended for the Periodical Occupancy Renewal Certificate to the above said Educational building.

- (4) **In view of the above and as recommended by the Inspection Committee, Fire Prevention Wing, Vijayawada Municipal Corporation, the Periodical Occupancy Renewal Certificate is hereby issued to the Existing Non Multi Storied Educational building of N.St. Mathew's Public School located at D.No.69-1-5A,Patamata,Vijayawada (City),NTR District with Ground + 02 Upper floors with a height of 11.34 Mtrs and total built up are is 11,671.98 Sq. Mtrs and subject to the following conditions.**

Sl No	As Builder	As Occupant	As Security Personnel
(i)	All the Fire protection arrangements shall be maintained in good working as seen during Inspection	All the Escape / Exit routes shall not be kept locked/blocked or encroached	All the occupants must know the correct method of operation of the Fire fighting system installed
(ii)	Any loss of life or property due to Non-functioning of Fire Safety Measures and other installations shall be the responsibility of the Management	All the Occupants shall be trained to operate the Fire Safety Equipments during Emergency	Mock drills should be conducted once in 3 months for initial two years. Thereafter, once in every 6 months
(iii)	Addition/Alteration, if any in the building may be verified by the building Authority	Mock drills should be conducted once in 3 months for initial two years. Thereafter, once in every 6 months	All Security personnel shall be trained to operate the Fire Safety Equipments during Emergency
(iv)	This No objection Certificate for occupancy is only in Fire Safety point of view	Raise the alarm if the Fire cannot be controlled; Evacuate the area completely at once with nearest safe exit.	Attack the Fire using available Fire Equipment only if you feel capable of controlling. If not, take all steps to isolate the area by closing doors and windows

(5) The Management shall ensure the following conditions of the building:

- (i) It is the responsibility of the Management to maintain Fire Fighting Systems in good working condition at all times.
- (ii) The Management is responsible for all risks involved in case of Fire Accident.
- (iii) This Periodical Occupancy Renewal Certificate with condition that all the Fire Fighting systems is periodically tested, repaired and maintained.
- (iv) If any deviation noticed will lead to cancellation of Periodical Occupancy renewal Certificate without any notice.

(6) This Periodical Occupancy Renewal Certificate is valid for a Period of Three (3) Years from the date of issue and the Management of N.St. Mathew's Public School shall submit the application for the Periodical Occupancy Renewal Certificate duly remitting the User charges as per G.O Ms No.218, Home (Prisons & Fire) Department, dated: 22-12-2023, Two (2) months before expire of this No Objection Certificate.

**Sd/-
Commissioner
Vijayawada Municipal Corporation**

**To,
N.St. Mathew's Public School,
D.No.69-1-5A, Patamata, Vijayawada (City), NTR District.**

Copy to the District Disaster Response and Fire Officer, NTR District, Vijayawada.

Copy to the District Educational Officer, NTR District, Vijayawada.

//t.c.f.b.o//


**District Fire Officer &
Regional Fire Officer, I/c**
